

Facility Summary in PETROLEUM County in the City of WINNETT

Location: WINNETT TIRE
115 N BROADWAY
WINNETT, MT 59087 PETROLEUM
Contact: (406) 429-2961

Sys Fac ID: 35-00536
Last Inspected On: 4/11/2013
Operating Permit Renewal Date: 6/17/2016

Owners/Operators: GS Oil Inc Roy, Owner (406)-464-2221 PO BOX 149
ROY MT 59471-0149
Jolene Smith, UST Class A Operator
Jolene Smith, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	16	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4094	Yes	5/23/2013	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
2,000					
4	16	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4095	Yes	5/23/2013	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
3,000					
5	16	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4096	Yes	5/23/2013	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000					
6	16	9/27/1999	Bare Steel	Flexible Plastic	High Level Alarm
4097	Yes	5/23/2013	Double-Walled	Double-Walled	No
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
3,000					

Facility Summary in PETROLEUM County in the City of WINNETT

Location: B & D SERVICE HWY 244
203 N BROADWAY AVE RR 244
WINNETT, MT 59087 PETROLEUM

Sys Fac ID: 56-13897

Last Inspected On: 8/19/2015

Operating Permit Renewal Date: 1/26/2019

Contact: David Grantier, (406) 429-5291

Owners/Operators: B & D Service, Owner

(406)-429-5291

PO BOX 229

WINNETT MT 59087-0229

Becky Grantier, UST Class A Operator

David Grantier, UST Class A Operator

Becky Grantier, UST Class B Operator

David Grantier, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	16	4/1/1999	Unknown	Flexible Plastic	
4001	Yes	8/19/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			ILS-350 , Veeder Root		
6	16	4/1/1999	Unknown	Flexible Plastic	
4002	Yes	8/19/2015	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			ILS-350 , Veeder Root		